6625349373

TOTALE - WATER SUPPLY

	MISSISSIPPI STATE DEPARTMENT OF HEALTH
	RUREAU OF PURITO WATER SUPPLY
	CCR CERTIFICATION FORM  CALENDAR YEAR 2012 -  Apine Wa fee HS Lieu Leil  Fublic Water Supply Name
	Hoine Water HSS Clarell
	Public Water Supply Name
	List PWS ID #s for all Community Water Systems included in this CCR
	·
Co sy ou of ch	he Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water stem, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the estomers upon request. Make sure you follow the proper procedures when distributing the CCR. Since this is the first year electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Pleas teck all boxes that apply.
C	Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
	O Advertisement in local paper (attach copy of advertisement)
	On water bills (attach copy of bill)  Email message (MUST Email the message to the address below)  Other
	Date(s) customers were informed: / / / / / /
ם	CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used
	Date Mailed/Distributed: / /
0	CCR was distributed by Email (MUST Email MSDH a copy)  As a URL (Provide URL  As an attachment  As text within the body of the email message
e	CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
	Name of Newspaper: Northeast Mississippi Daily Journal
	Date Published: 06/16/13
]	CCR was posted in public places. (Attach list of locations)  Date Posted: / /
]	CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED);
ber ubl ie S	reby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this ic water system in the form and manner identified above and that I used distribution methods allowed by SDWA. I further certify that the information included in this CCR is true and correct and is consistent with water quality monitoring data provided to the public water system officials by the Mississippi State arment of Health, Bureau of Public Water Supply.

10 ne Tule (President, Mayor, Owner, etc.)
Secsetary

eliver or send via U.S. Postal Service: creau of Public Water Supply O. Box 1700 ckson, MS 39215

May be faxed to: (601)576-7800

May be emailed to: Melanic. <u>Yanklowski@msdh.state.ms.us</u>

2013 JUN 17 PM 3: 0!

#### 2012 Annual Drinking Water Quality Report Alpine Water Association PWS#: 0730001 June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eutaw Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Alpine Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Teresa O'Callaghan at 662.869.2049. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular scheduled meetings held on the second Tuesday of March, June, September and December at 7:00 PM at the Alpine Fire Department.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) — The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST RES	ULTS				
Contaminant	Violation Y/N			Level Range of Detects Oetected or # of Samples Exceeding MCL/ACL		Unit MCLG Measure- ment		Likely Source of Contamination	
	Contami	inants							
Inorganic	Contain								

13. Chromium	N	2010*	3.1	1.7 – 3.1	ppb	100	100	Discharge from steel and pulp milts; erosion of natural deposits
14. Copper	N	2009/11*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2010*	.137	.129137	ppm	4		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010*	1.7	1.5 1.7	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection	n By-l	Products						
Chlorine	orine N 2012 1.2		.7 – 1.9 mg/l		1 1		Water additive used to control microbes	

<sup>\*</sup> Most recent sample. No sample required for 2012.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

## \*\*\*\*\*April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Alpine Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

## Northeast Mississippi Daily Journal

06/13/13

1242 S. Green Street P.O. Box 909 **Tupelo, MS 38804** 

Classified (662) 842-2622 Fax: (662) 620-8301

Email: classifieds@journalinc.com

Name: Company: **TERESA O'CALLAGHAN** 

**ALPINE WATER ASSOCIATION** 1128 HWY. 9 NORTH

Address:

**BLUE SPRINGS, MS 38828** 

Account ID:

7159460

Account #:

Telephone:

(662) 316-6194 Fax:

E-mail:

(662) 539-3975 tocallaghan@standex.com

SIC code:

Publications:

**Daily Journal** 

Run dates: Class:

06/16/13 to 06/16/13 1401

Ad ID: Ad Taker:

848050 **JSH** 

Sales Person: C07

Inserts:

Words: 1588 Lines: 122 Columns: Depth (Inches): 13.5

Payments: Method

Card Туре

Name on Card Last 4 Digits Expire Date

Check Number

Amount Paid

Net Cost:

\$196.56

Paid Amount: - \$0.00

Amount Due: \$196.56

Publication	Sta	<u>ırt Sto</u>	p	Inserts	Cost	
Daily Journal	06/16/13	06/16/13	1	\$196.56		

Ad Notes MAILING CHECK

# Northeast Mississippi Daily

#848050

#### **LEGAL NOTICE**

2012 Annual Drinking Water Quality Report Alpine Water Association PWS#: 0730001 June 2013

We're pleased to present to you this year's Annual Quality water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Eulaw Formation Aquiler.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Alpine Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Teresa O'Callaghan at 662.869.2049. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the regular scheduled meetings held on the second Tuesday of March, June, Soptember and December at 7:00 PM at the Alpine Fire Department.

second Tuesday of March, June, September and December at JULY MIR at time Applier are Expartments. We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbal contaminants, such as viruses and bacteria, that may come from sewage treatment plants, spetic systems, agricultural livestock operations, and wildlife; inorganic contaminants storm-water runoff, and residential uses, organic chemicals, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses, organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring to the threatile of all and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA preserbles regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking valers, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health, MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drunking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST R	ESULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Inorganic Cont	aminants	Avr.manne				- X.		
10. Barlum	N	2010*	.13	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010*	3.1	1.7 - 3.1	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2009/11*	.1	0	ррп	1.3	AL≃1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2010*	137	.129137	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	1	0	фрр	0	Al.=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010*	1.7	1.5 - 1.7	ppb	50	50	Discharge from petroleum and meta refineries; erosion of natural deposits; discharge from mines
Disinfection By	-Products							
Chlorine	N	2012	1,2	.7 - 1.9	mg/i	0	MDRL=4	Water additive used to control microbes

Most recent sample. No sample required for 2012.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead con cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sulting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested, indentation on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead Lesting. Please contact 601,576,7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of containmants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hottline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EP3/CDC guidelines on appropriate means to lessen the risk of infection by cryptospondium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

## \*\*\*\*\*April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water suppliers were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deatiline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Alpine Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

June 16, 2013